

2007 WATER QUALITY REPORT FOR NORTH LIBERTY WATER DEPARTMENT

This report contains important information regarding the water quality in our water system. The source of our water is groundwater. Our groundwater is drawn from the Silurian and Cambrian Jordan Sandstone aquifers. Our water quality testing shows the following results:

CONTAMINANT	MCLG	MCL	DETECTED LEVEL	DATE SAMPLED	RANGE OF DETECTION	VIOLATION	SOURCE
Copper (ppm)	1.3	AL=1.3	0.8	7/06	0.06 – 0.93	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead (ppb)	0	AL=15	0	7/06	0 - 0	No	Corrosion of household plumbing systems; erosion of natural deposits
Nitrate [as N] (ppm)	10	10	1.2	2007		No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Combined radium (pCi/L)	0	5	1.3	4/24/06		No	Erosion of natural deposits
Alpha emitters (pCi/L)	0	15	3	4/24/06		No	Erosion of natural deposits
Sodium (ppm)	N/A	N/A	310	7/16/07		No	Erosion of natural deposits; Added to water during treatment process
TTHM (ppb) [Total trihalomethanes]	N/A	100	5.7	7/31/07		No	By-products of drinking water disinfection
Fluoride (ppm)	4	4	1.07	1/19/06		No	Water additive which promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories
Chlorine (ppm)	MRDLG =4.0	MRDL=4.0	1.20	2007 Running annual average	0.75-1.54	No	Water additive used to control microbes

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

DEFINITIONS

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) -- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ppb -- parts per billion.
- ppm -- parts per million.
- pCi/L – picocuries per liter
- N/A – Not applicable
- ND -- Not detected
- Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Maximum Residual Disinfectant Level (MRDL) – The highest level of s disinfectant allowed in drinking water. There is convincing that addition of a disinfectant is necessary for control of microbial contaminants.

GENERAL INFORMATION

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. North Liberty is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

SOURCE WATER ASSESSMENT INFORMATION

The North Liberty water supply obtains its water from the Silurian and Cambrian Jordan Sandstone aquifers. The Silurian and Cambrian Jordan Sandstone aquifer were determined to be not susceptible to contamination because the characteristics of the aquifer and overlying materials prevent easy access of contaminants to the aquifer. The wells will not be susceptible to most contaminant sources except through pathways to the aquifer such as abandoned or poorly maintained wells. A detailed evaluation of your source water was completed by the IDNR, and is available from the North Liberty Water Department at 319/626-5719.

CONTACT INFORMATION

For questions regarding this information, please contact the North Liberty Water Department at 319/626-5719 during the following hours: 7:00 am – 3:30 pm.

Decisions regarding the water system are made at the city council meetings held on the second Tuesday at 7 p.m. at 25 W. Cherry Street and are open to the public.